



QIJW.E489271 - Photovoltaic Rapid Shutdown System Equipment

Photovoltaic Rapid Shutdown System Equipment

See General Information for Photovoltaic Rapid Shutdown System Equipment

IMO PRECISION CONTROLS LTD

The Interchange Frobisher Way
Hatfield, AL10 9TG UNITED KINGDOM

E489271

Cat. No.	Function	Ratings
Photovoltaic rapid shutdown system equipment		
FRS-ESW1, FRS-ESW2	Actuator	115 V ac, max 40°C ambient Class 2 output
Photovoltaic rapid shutdown system equipment		
FRS-01, FRS-02, FRS-03, FRS-04	Isolator	150 V dc, 12 A max with 11 AWG cable, max. 55°C ambient
Photovoltaic rapid shutdown system equipment		
FRS-CBLD, FRS-CBLD1, FRS-CBLD2	Attenuator	1000 Vdc, 12 A max with 11 AWG cable, max. 55 °C ambient

Last Updated on 2020-09-14

The appearance of a company's name or product in this database does not in itself assure that products so identified have been manufactured under UL's Follow-Up Service. Only those products bearing the UL Mark should be considered to be Certified and covered under UL's Follow-Up Service. Always look for the Mark on the product.

UL permits the reproduction of the material contained in the Online Certification Directory subject to the following conditions: 1. The Guide Information, Assemblies, Constructions, Designs, Systems, and/or Certifications (files) must be presented in their entirety and in a non-misleading manner, without any manipulation of the data (or drawings). 2. The statement "Reprinted from the Online Certifications Directory with permission from UL" must appear adjacent to the extracted material. In addition, the reprinted material must include a copyright notice in the following format: "© 2020 UL LLC"

Reprinted from the Online Certifications Directory with permission from UL